

April 26, 2022

Paul Deel  
P.O. Box 328  
Newberry Springs, CA 92365  
760-257-3606

2022 Board of Directors  
Newberry CSD  
30884 Newberry Rd.  
Newberry Springs, CA 92365

RE: Observations of the new water system


Greetings Board of Directors,

I have observed the completed installation of the new water system additions and alterations serving the park grounds and community building.

1. The existing cross connection between the ball field irrigation system and park restrooms was not addressed.
2. The existing back flow preventer to the ball field sprinkler system was removed.
3. The new additions and alterations included the addition of 2 new cross connections. Cross connections are a violation of the UPC (Uniform Plumbing Code) Chapter 6. If my observations are correct, this means that the entire water system on the property and in the buildings is now non-potable and must be labeled as such.

I am requesting this board to: (1) have the cross connections removed or corrected to be in compliance with UPC Chapter 6 para. 603.1-5; or (2) install the required labeling of the system and faucets as required in UPC Chapter 6 para. 601.3. "CAUTION: NON-POTABLE WATER, DO NOT DRINK"

Respectfully submitted,



Paul Deel

NOTE: I ask that this letter be included with the recorded minutes of this CSD meeting of 4/26/2022.